



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 398-07-M

**Manufacturers:** Euro Panels Overseas N.V.  
Bormstraat 22, B-2830 Willebroek  
Belgium  
&  
American Fiber Cement Corp.  
6901 S. Pierce Street, Suite 260  
Littleton, CO 80128

**Trade Name(s):** Eter-Color

**Product:** Non-combustible façade panel

**Pertinent Code Section(s):** 27-348, 27-335-1

**Prescribed Test(s):** RS 5-5 (ASTM E136), Toxicity

**Laboratory:** SGS U.S. Testing Company, Inc. (SGS)  
Anderson Laboratories, Inc. (AL)

**Test Report(s):** SGS Test #177:007388  
AL Test #668, dated October 1, 2007.

**Description:** Eter-Color is a non-flammable, through-colored, fiber cement board for façade and exterior/interior cladding. Eter-color has a high-resistance to severe weather conditions as well as chemicals and living organisms. Eter-color panel has 6mm and 8mm thickness in trimmed and untrimmed sizes, available in various colors and retains the ASTM E136 and toxicity rating per building code requirements.

**Terms and Conditions:** The above-described panel is accepted for interior and exterior finish usage with the following conditions:

1. Panel is to be hung in accordance with the New York City Building Code.
2. All safety precautions must be adhered to when hanging panel in accordance with OSHA standards or Building Department standards, whichever provides the highest degree of safe handling.
3. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials are equivalent to those tested and accepted for use, as provided for in Article 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 23, 2008

Examined By Simon Derkshidam